

Missouri Department of Natural Resources



PUBLIC NOTICE

DRAFT MISSOURI STATE OPERATING PERMIT

DATE: July 14, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, Southeast Regional Office, 2155 N. Westwood Blvd., Poplar Bluff, Missouri, 63901, ATTN: Gary L. Gaines, P.E., Regional Director. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by August 13, 2006 or received in our office by 5:00 p.m. on August 16, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.


Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.mo.gov/env/wpp/wpcp-pn.htm>, or at the Department of Natural Resources, Southeast Regional Office, 2155 N. Westwood Blvd., Poplar Bluff, Missouri, 63901, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: July 14, 2006
Permit Number: MO-0087025
Southeast Regional Office

FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
Potosi Elks Lodge #2218 10202 West State Hwy E Potosi, MO 63664	Potosi Elks Lodge #2218 P.O. Box 177 Potosi, MO 63664
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
Unnamed Trib. to Mine A Breton Creek(U) NW ¼, Sec. 12 (projected), T37N, R2E, Washington County	Domestic, reissue

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0087025

Owner: Potosi Elks Lodge #2218
Address: P.O. Box 177, Potosi, MO 63664

Continuing Authority: Same as owner
Address: Same as owner

Facility Name: Potosi Elks Lodge #2218
Facility Address: 10202 West State Hwy E, Potosi, MO 63664

Legal Description: NW ¼, Sec. 12 (projected), T37N, R2E, Washington County
Latitude/Longitude: +3756400/-09046180

Receiving Stream: Unnamed Tributary to Mine A Breton Creek (U)
First Classified Stream and ID: Mine A Breton Creek (P)(2101)
USGS Basin & Sub-watershed No.: (07140104-040002)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Domestic/Club - SIC #4952
Single cell lagoon/sludge is retained in basin.
Design population equivalent is 7.
Design flow is 700 gallons per day.
Actual flow is 700 gallons per day.
Design sludge production is .11 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

Expiration Date
MO 780-0041 (10-93)

Gary L. Gaines, P.E., Director, Southeast Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 2 of 4	
					PERMIT NUMBER MO-0087025	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Flow	MGD	*		*	once/quarter**	24 hr. estimate
Biochemical Oxygen Demand ₅	mg/L		65	45	once/quarter**	grab
Total Suspended Solids	mg/L		120	80	once/quarter**	grab
pH - Units	SU	***		***	once/quarter**	grab
Ammonia as N	mg/L	*		*	once/quarter**	grab
Temperature	°C	*		*	once/quarter**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

* Monitor and report.

** See table below for quarterly sampling

Sample discharge at least once for the months of:	Report is due:
January, February, March (1 st Quarter)	April 28
April, May, June (2 nd Quarter)	July 28
July, August, September (3 rd Quarter)	October 28
October, November, December (4 th Quarter)	January 28

*** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

C. SPECIAL CONDITIONS (continued)

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

5. Report as no-discharge when a discharge does not occur during the report period.
6. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (e) There shall be no significant human health hazard from incidental contact with the water;
 - (f) There shall be no acute toxicity to livestock or wildlife watering;
 - (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

C. SPECIAL CONDITIONS (continued)

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part VII shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

D. SCHEDULE OF COMPLIANCE

1. An engineering report prepared by a licensed professional engineer registered in the State of Missouri must be submitted for review by May 1, 2007. The engineering report must describe the current treatment system and list alternatives for wastewater treatment or show that the existing system will meet the current standards.
2. If engineering report indicates upgrades are needed, plans and specifications must be developed for the wastewater treatment system improvements. The plans and specifications will be submitted with a construction permit application for review and approval by December 1, 2008.
3. Complete upgrades to the wastewater treatment system authorized under a construction permit by May 1, 2010.



Missouri Department of Natural Resources
Water Protection Program
Water Pollution Control Branch
NPDES Permits and Engineering Section

Water Quality Review Sheet Check List
Lagoon Operating Permit Renewal

Facility Information

Facility Name: Potosi Elks Lodge #2218 Permit #: MO-0087025
Facility Type: Single cell lagoon Age: 16+Years

Outfall Characteristics

Outfall	Design Flow (MGD)	Actual Flow (MGD)	Actual Flow/Design Flow
001	.0007	.0007	100%

Effluent Characteristics

Biochemical Oxygen Demand (BOD5) In Compliance ☐ Significant Noncompliance ☐ Unknown X
Total Suspended Solids (TSS) In Compliance ☐ Significant Noncompliance ☐ Unknown X
Percent Removal (>65%) BOD & TSS In Compliance ☐ Significant Noncompliance ☐ N/A X

Effluent Limit/Monitoring Requirement Frequency at regulatory minimum: Yes X No ☐

Receiving Waterbody Information

Waterbody Name: Unnamed Tributary to Mine A Breton Creek Class: U
Waterbody Name: _____ Class: _____

Discharge to or within two (2) miles of a losing stream (10 CSR 20-7.031, Table J or as determined by GSRAD) ☐

Discharge to or within two (2) miles of a classified waterbody designated for whole body contact recreation ☐

Use Attainability Analysis Conducted ☐

Stream Survey Conducted within the past five (5) years ☐ Observed water quality impacts ☐

If the facility discharges to any of the waterbody types below, is within an area experiencing rapid development, or if a site-specific water quality impact study has been conducted, this form is not applicable.

Lake/Reservoir ☐ 303(d) Waterbody ☐ Metropolitan No-Discharge Stream ☐

Outstanding National/State Resource Water and Drainages Thereto ☐